intertek
Total Quality. Assured.

Certificate of Conformity

Certificate Number: CN-PVES-250144

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Zendure USA Inc. 1765 E BAYSHORE RD # 201 EAST PALO ALTO, CA 94303-5501 USA
Product:	SolarFlow 2400 AC Coupled Inverter
Ratings & Principle Characteristics:	See appendix of Certificate of Conformity
Model:	ZDSF2400AC
Brand Name<s>:	ZENDURE SuperCharged+-
Product Complies with:	EN 50549-1: 2019+A1:2023, Requirements for generating plants to be connected in parallel with distribution networks Part 1: Connection to a LV distribution network - Generating plants up to and including type B EN 50549-10:2022, Requirements for generating plants to be connected in parallel with distribution networks - Part 10: Tests for conformity assessment of generating units Netherlands considered and Type approval for type A and B
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
Test Report No.<s>:	250327092GZU-001, 28 Mar 2025

According to Annex H of the standard EN 50549-1:2019, generating plants compliant with the clauses of this European Standard are considered to be compliant with the relevant Article of COMMISSION REGULATION (EU) 2016/631, provided that all settings as provided by the DSO and the responsible party are complied with.
Additional information in Appendix.

Signature

Certification Manager: Grady Ye
Date:03 April 2025

ACCREDIA
L'ENTE ITALIANO DI ACCREDITAMENTO

PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250144

Model	ZDSF2400AC
Battery voltage Range	37.5-54.75 V dc
Battery charge current	60 A dc
Battery discharge current	54.17 A dc
Nominal output voltage	230 V ac
Nominal output Frequency	50 Hz
Max. output current	10.43 A
Max. output power	2400 W
Max. apparent power	2400 VA
Power factor range	0.8leading~0.8lagging
Safety level	Class I
Ingress Protection	IP 65
Operation Ambient Temperature	-20℃ - +60℃
Software version	V1

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.